

Section 02613 S

BAR WRAPPED CYLINDER PIPE

The following supplements modify Section 02613 – Bar Wrapped Steel Cylinder Pipe Standard Specification. Where a portion of the Specification is modified or deleted by this Supplementary Specification, the unaltered portions of the Specification shall remain in effect.

2.01 MATERIALS: Delete Paragraph 2.01 E and replace with the following:


- E. Pipe Manufacturer: Refer to Specification Section 02511 - Water Mains for performance history requirements.

Delete Paragraph 2.01 I.2 and replace with the following:

- 2. Rubber-Gasketed Joints: Attach joint ring to steel cylinder with full-thickness fillet welds, welded inside and out (double welded). Bond as shown on Drawings to provide electrical continuity along pipeline.

END OF SUPPLEMENT

Approved by:



Hamlet Hovsepian, P.E.
Managing Engineer
Engineering and Construction Division

Date 9/7/05